

Smart Meter TESTING REPORT

March 2021

Meter Farm Environmental Testing				
Category	Volume	Install Date	Status	Notes
Stratus IQ Forward-Only Meters	8	30-Oct-19	Pass	No signs of Environmental Contamination
Stratus IQ Bi-Directional Meters	12	30-Oct-19	Pass	No signs of Environmental Contamination

Technical Services and Research Physical Stress Testing		
Category	Status	Notes
Internal Protection Voltage Threshold Test	Pass	N/A
Disconnect Switch Thermal Behaviours	Pass	N/A
Overcurrent Disconnect Switch Test	Pass	N/A
Overvoltage Test	Pass	N/A
Extreme Temperature Testing	Pass	N/A

Radiofrequency Emissions Testing		
Category	Status	Notes
Limits of Human Exposure to Radiofrequency Electromagnetic Energy in the Frequency Range from 3 KHz to 300 GHz per Health Canada Safety Code 6	Pass	N/A